

# URBAN HEALTH CENTRE

(Managed by Vapi Nagar Palika, Govt. of Gujarat)  
Geeta Nagar, Vapi (East), Gujarat – 396191.

No. 652

Date:08/08/2023

## SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

It is certified that an inspection team headed by Dr. Vini Ashishkumar Patel, Medical Officer from Urban Health Centre, Geetanagar, Vapi inspected the Shree Jain Yuvak Mandal English Medium School, situated Nr. Old Railway Crossing, Vapi (East)-396191 on 08/08/2023 and found that the Shree Jain Yuvak Mandal English Medium School has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of 08/08/2028 with every year laboratory water testing report.

Dr. Vini Ashishkumar Patel  
Medical Officer  
UPHC, Geetanagar,  
Tal. – Vapi, Dist. – Valsad, Gujarat.

*V. Patel*

Urban Health Officer  
Geeta Nagar, Vapi.  
Tal. Vapi, Dist. Valsad

To  
Shree Jain Yuvak Mandal English Medium School  
Near Old Railway Crossing,  
Silvassa Road. Vapi (East) – 396191.



**Konark Research Foundation  
Testing & Calibration Laboratory**

Plot No.338/1, Behind Patel Cricket Ground, Kachigam, Daman& Diu, 396210  
Regd.Office:333, Adhyaru Industrial Estate,Sunmill Compound, Lower Parel, Mumbai (MH) 400013  
DD,INDIA  
saleskrf@konarkgroup.com

**TEST REPORT**

**Issued To :** Shree Jain Yuvak Mandal English Medium School Vapi  
Near Old Railway Crossing, Silvassa Road, Vapi.  
Valsad  
Valsad Valsad Gujarat 396130

LMR-FMT-PR-SRV-006-001  
MOEF Approved Laboratory  
**Certificate No. :** KRF/0258/WAT/24-25  
**Issued Date :** 20.07.2024

**Sample Name :** DRINKING WATER  
**Sample Received On :** 19.07.2024  
**Sample Quantity :** 1.0 Litre

Sr No	Test Parameters	UOM	Method	Detection Limit	Requirement	Test Reported Value
<b>Description :</b> Clear Colourless Liquid.						
1	Colour	Units	IS:3025 (PART-04)	---	NMT 5	Below-1
2	Odour	---	IS:3025 (PART-5)	---	Agreeable	Agreeable
3	Total Dissolved Solid	mg/Lit.	IS:3025 (PART-16)	---	NMT 500	148.00
4	pH	---	IS:3025 (PART-11)	---	6.5 to 8.5	6.68
5	Chloride	mg/Lit.	IS:3025 (PART-32)	---	NMT 250	15.00
6	Alkalinity	mg/Lit.	IS:3025 (PART-23)	---	NMT 200	40.66
7	Turbidity	NTU	IS:3025 (PART-10)	---	NMT 1	0.2
8	Residual free chlorine	mg/Lit.	IS:3025 (PART-26)	---	Min 0.2	Not Detected
9	Total Hardness	mg/Lit.	IS:3025 (PART-21)	---	NMT 200	36.05
10	Calcium	mg/Lit.	IS:3025 (PART-40)	---	NMT 75	7.22
11	Magnesium	mg/Lit.	IS:3025 (PART-46)	---	NMT 30	4.38
12	Iron	mg/Lit.	IS:3025 (PART-2)	---	NMT 1.0	0.002
13	E.Coli	---	IS 15185:2016	---	Absent /100ml	Absent/100ml
14	Coliform	---	IS 15185:2016	---	Absent /100ml	Absent/100ml

\*\*\*END OF REPORT\*\*\*

**Test Started on :** 19.07.2024  
**Test Completed on :** 20.07.2024

*Testing & Calibration Laboratory*

**MS. SONAL**

**Authorised Signatory-Micro**

**MR. GIRISH PATEL**

**Authorised Signatory-Chemical**

**Note :** This report is Subject to the terms & conditions mentioned overleaf.

\* Environmental Monitoring And Analysis \* Food & Drug Analysis \* GLP Facility For Agro Chemicals \* Ayurvedic Analysis